

GET-1032MM

Introduction:



The GET-1032MM controller is a flexible data logging device targeted at metering, energy monitoring and general data logging applications. Its Modbus Master capability provides a means of connecting to smart meters and other Modbus equipped devices for data logging and other purposes.

It provides a wealth of options for gathering data and storing it. In addition to the Modbus Master interface, it supports pulse metering devices via its digital inputs. Communications with the PC is via BACnet/IP over Ethernet. For remote data logging, the GET-1032 uses FTP to transfer the data logs as CSV files.

The controller provides 8 digital inputs, 8 digital outputs, 8 analog inputs and 8 analog outputs. This allows the GET-1032MM to record pulse meters, digital values, analog voltages, 4-20mA values and thermistor sensors.

Modbus Master

The Modbus Master functionality provides the ability to transfer up to 63 values from Modbus slave devices and present them as BACnet objects in the GET-1032MM. This allows the GET-1032MM act log data from Modbus devices and also act as a Modbus to BACnet gateway.

Modbus discrete inputs and coils can be linked to BACnet binary objects.

Modbus input registers and holding registers can be linked to BACnet analog objects. Single registers and pairs of registers can be mapped to allow transfer of 16bit integer, 32bit integer and 32bit floating point values.

The GET-1032 can talk to Modbus slaves via RS485 or RS232 and uses the Modbus RTU data format.

Remote Configuration

Remote configuration via FTP allows the GET-1032 automatically apply configuration changes without the need for site visits. A recovery mode allows untrained local staff initiate an update which can be applied from GLAS Energy Technology's servers.

GET-1032MM

Trend logs

The GET-1032 provides trend log storage in battery backed RAM for between 8 and 63 values depending on the number of readings required per value. In non-grouped configurations, the following combinations of log numbers and lengths are supported:

Number of logs	Readings per log	Days stored (15min interval)
8	4000	41
10	3200	33
16	2000	20
20	1600	16
25	1280	13
32	1000	10
40	800	8

Grouping of trend logs can provide up to 63 logs of 1000 entries each with common time bases.

The on board Real Time Clock provides time stamping down to 1 second resolution for all trend log readings and the time can be synchronised to internet time servers for automatic time correction

Schedules

The GET-1032MM supports 8 BACnet schedules with 10 switching times per day each. These can be used to provide time control of external devices via the digital outputs or can be used with the logged data to provide alerts for “out of hours” usage to help track leaks or energy wastage due to lights or equipment being left on for example.

BACnet support

The GET-1032MM controller supports BACnet/IP communications. The following BACnet objects are supported:

Accumulators, Analog Inputs, Analog Outputs, Analog Values, Binary Inputs, Binary Outputs, Binary Values, Device, Schedules, Trend Logs

The mapping of physical I/O points to BACnet objects is very flexible and supports the following combinations:

BACnet Object	Possible Physical I/O
Accumulator	Pulse inputs, Modbus values
Analog Inputs	Analog inputs, pulse inputs, Modbus values
Analog Outputs	Analog outputs, PWM digital outputs
Analog Values	Analog inputs, pulse inputs, Modbus values
Binary Inputs	Binary inputs, analog inputs
Binary Outputs	Binary outputs, analog outputs
Binary Values	Binary outputs, analog outputs, Modbus values

Inputs/Outputs

8 Digital inputs – These can be used for normal digital input operation or for pulse counting.

8 Analog Inputs – These inputs have 12 bit resolution. They can be used for 0-10Vdc, 0-20mA/4-20mA, Temperature Sensors, binary input – no pulse capability.

8 digital Outputs – These Darlington pair outputs can be used as sinking digital outputs for up to 50V loads. Outputs 1 and 5 have a single Darlington pair driving the pins. All other outputs have 2 Darlington pairs in parallel to provide a higher drive current. Pass through mode allows digital outputs replicate pulses from digital inputs to avoid the need for pulse splitters in many applications.

8 Analog Outputs – 0-10Vdc, 12 bit resolution, maximum current capability is 20mA. It is not recommended to have maximum current on all outputs simultaneously. They can also be operated as 0-10Vdc binary outputs.

GET-1032MM

Communications Interfaces:

The GET-1032MM comes equipped with a comprehensive collection of communications ports to ensure maximum flexibility.

Port	Protocols
RS485 Port A	Modbus Master
RS485 Port B	BACnet MS/TP (firmware option)
RS232	Modbus Master
Mini USB	FTDI Serial interface for firmware upgrade
Ethernet 10baseT	BACnet/IP, SMTP for email alerts, remote firmware upgrade

LEDs

There are several LEDs on board which indicate different statuses:

LED	Function
Power	Green LED for power OK
ZigBee Status	Green LED indicating status of ZigBee connection
Config/Status	Green LED. Flashes once per second in normal operation and more frequently for fault indication. Also used when config button is pressed
RS485 port A TX	Green LED. Flashes for transmit data
RS485 port A RX	Yellow LED. Flashes for receive data
RS485 port B TX	Green LED. Flashes for transmit data
RS485 port B RX	Yellow LED. Flashes for receive data
Ethernet Link	Orange LED, Ethernet link up
Ethernet Activity	Green, flashes for network traffic

Specifications:

Dimensions:	213mm x 110mm x 33mm
Mounting:	DIN rail mounting or wall mounting via integral slots on base.
EMC Immunity:	EN6100-4-2 (ESD), EN6100-4-3 (Radiated Immunity), EN6100-4-4 (EFT), EN6100-4-6 (Conducted Immunity). Additional shielding or filtering may be required for heavy industrial environments. Maximum allowed cable lengths of 10m.
EMC Emissions:	CISPR 22 Class B, FCC Part 15 Class B. Your results may vary, depending on your application, so additional shielding or filtering may be needed to maintain the Class B emission qualification. Maximum allowed cable lengths of 10m.
Power Supply:	12Vdc, 300mA
Fuse:	1000mA resettable.
Operating Environment:	0°-50°C, Maximum Relative Humidity 70%

The GET-1032MM is  qualified.

GET-1032MM

Connections:



RS232 Pinout

1 – no connection (DCD), 2 – RxD, 3 – TxD, 4 – no connection (DTR), 5 – Gnd, 6 – no connection (DSR), 7 – RTS, 8 – CTS, 9 – no connection (RI)

Further Information:

For more information please contact:

GLAS Energy Technology,
Johnstown Business Centre,
Johnstown House,
Johnstown,
Naas, Co. Kildare,
Ireland

+353 (0) 818 227050

www.glasenergytechnology.ie

info@glasetch.ie

GET-1032MM Datasheet ©Copyright 2020 GLAS Energy Technology

Page 4 of 4

Rev 1.4